

Heat Transfer Products Group, LLC A Division of Rheem Manufacturing 201Thomas French Drive Scottsboro, Alabama 35769

SUBJECT: Wind Load Analysis of HTPG "3 TO 22 HP, Next-Gen II Series" Air Cooled Condensing Unit Models

The following wind load analysis applies to all 3 TO 22 HP HTPG "Next-Gen II Series" Air Cooled Condensing Units using the following model nomenclature:

Date: 10 October 2024

R	F	D	Т	03	M	48	E	Α
1	2	3	4	5	6	7	8	9

The listing below are the positions for the new model with a brief explanation:

1 Branding: R Russell W Witt K Kramer C ColdZone H HTPG ? Other brands may use single letter code or asterisk "*"

2 Condenser and Control Type: B No flooded condenser control (Indoor or Warm Climate Outdoor) F Flooded Condenser Control (Outdoor)

3 Compressor Type: C Carlyle B Bitzer D Discus S Semi-Hermetic O Scroll

Compressor Configuration: S Series Single T Series Dual

Nominal Size: XX Two numbers roughly equal to compressor horsepower

Temperature Range: L Low M Medium E Extended Medium

Refrigerant Type: 44 R404A 48 R448A or R449A 4S compressor is rated for all refrigerants.

4A A2L Refrigerants R454A/R454B/R454C/R455A/R328

8 Voltage/Phase/Frequency Code: C 230/1/60 D 208-230/1/60 E 208-230/3/60 G 460/3/60 V 208/3/60 W 230/3/60 Q 575/3/60

Revision Code: Starting with Letter A

The wind load analysis has determined both single and dual series "Next-Gen II Series" air cooled condensing units are in accordance with ASCE/SEI 7-22 Florida Building Code Eighth Edition (2023) for the following location:

Installation location: Miami – Dade County, Florida Installation Height: 60 feet

Roof Mounting Requirement										
	Number of	Max. Force at Each	Max Unit, Hurricane Net							
Cabinet Size	Attachment Points	Hurricane Tension, Net Uplift Load (lbs)	Hurricane Shear, Horizontal Load (lbs)	Overturning Moment (lbs.ft)						
FD1	6	568	249	3,176						
FD2	6	523	360	5,981						
FD3	6	616	435	7,014						

Using a roof curb to install these condensing units requires a metal mounting surface with stand details to be provided by the selected mechanical contractor at the job site.

