



Heat Transfer Products Group, LLC
 A Division of Rheem Manufacturing
 201 Thomas French Drive
 Scottsboro, Alabama 35769

Date: 10 October 2024

SUBJECT: Wind Load Analysis of HTPG ½ to 3½ HP Multi-Refrigerant Package Units

The following wind load analysis applies to all HTPG Multi-Refrigerant Package Units using the following nomenclature description:

R	P	O	150	M	48	D	A
1	2	3	4	5	6	7	8

The listings below are the positions for the model with a brief explanation.

- 1 **Branding:** R Russell W Witt K Kramer C ColdZone H HTPG ? Other brands may use single letter code or asterisk “*”
- 2 **Product Type:** P Package Refrigeration System
- 3 **Compressor Type:** H Hermetic O Scroll
- 4 **Horsepower:** XXX Three numbers roughly equal to compressor horsepower times 100
- 5 **Temperature Range:** L Low Temp M Medium Temp D Medium Temp Electric Defrost
- 6 **Refrigerant Type:** 44 R404A 48 R448A or R449A 4S compressor is rated for all refrigerants.
4A A2L Refrigerants R454A/R454B/R454C/R455A/R32
- 8 **Voltage/Phase/Frequency Code:** A 115/1/60 C 230/1/60 D 208-230/1/60
- 9 **Revision Code:** Starting with letter A

The wind load analysis has determined these multi-refrigerant air cooled condensing units are in accordance with ASCE/SEI 7-22, Florida Building Code Eighth Edition (2023) for the following location:

Installation location: Miami – Dade County, Florida

Installation Height: 60 feet

Roof Mounting Requirement				
Cabinet Size	Number of Attachment Points	Max. Force at Each Attachment Point		Max Unit, Hurricane Net Overturning Moment (lbs.ft)
		Hurricane Tension, Net Uplift Load (lbs)	Hurricane Shear, Horizontal Load (lbs)	
Small	6	480	169	2,018
Small w/ Roof Acc.	6	806	213	3,405
Large	6	483	169	2,384
Large w/ Roof Acc.	6	805	218	3,995

Using a roof curb to install these condensing units requires a metal mounting surface with stand details to be provided by the selected mechanical contractor at the job site.

